



190190

EMERGENCY SHOWERS AND EYEWASHES - SHOWERS AND EYEWASH SPARE PARTS

Maintenance table



The operation of the Emergency Showers and Eyewashes should be verified at least ONCE a week in order to guarantee the water supply and to prevent the proliferation of bacteria.